



USB/RS-485 INTERFACE CONVERTER PD10 TYPE



USER'S MANUAL



Contents

1. APPLICATION	5
2. CONVERTER SET	5
3. CONVERTER INSTALLATION	6
3.1. Converter installation and safety requirements	6
3.2. Description of converter leads	7
3.3. Installation of the COM port for Windows	8
3.4. Installation of COM port controllers on the computer.....	8
3.5. Example of Lumel Heat and Lumel 3000 configuration to co-operate with PD10.....	11
4. OPERATION DESCRIPTION	11
5. TECHNICAL DATA	12
6. EXECUTION CODES AND ORDERING	13
7. MAINTENANCE AND GUARANTEE	14

1. APPLICATION

The PD10 converter is a device which transmits data from the USB interface to the RS-485 industrial interface. USB interface, as the first, is destined to communicate with the device having a USB Host port, which is the most frequently a PC computer.

The RS-485 interface, as the second, is destined to communicate with devices in the object side. The maximal baud rate is 1 Mb/s. This baud rate depends on the RS-485 cable length. The converter does not interfere in the structure of transmitted data and is compatible with several industrial communication protocols, e.g. Modbus RTU, Modbus ASCII, a.s.l. In order to protect devices at both sides of interfaces, a galvanic separation is applied.

A program controller of the virtual serial port COM for the computer PC is added to the set.

It allows to exchange data by master programs with industrial objects through the P10 converter.

2. CONVERTER SET

The PD10 converter set includes:

- PD10 converter 1 pc
- User's manual 1 pc
- Guarantee card 1 pc
- USB cable of 1.8 m long 1 pc
- CD with drivers 1 pc

When unpacking the converter, please check the set completeness and whether the type and execution code on the data plate correspond to the order code.

3. CONVERTER INSTALLATION

3.1 Converter installation and operational safety

The converter is a portable device supplied from the USB bus. Dimensions of the converter are presented on the fig. 1.




Fig.1 Overall dimensions of the PD10 converter

In the safety service scope, the PD10 converter meets to requirements of the EN 61010-1 standard.



Observations concerning the operational safety

- All operations concerning transport, installation, and commissioning as well as maintenance, must be carried out by qualified, skilled personnel, and national regulations for the prevention of accidents must be observed.
- Before switching converter on, one must check the correctness of connection to the network.
- Do not connect the converter to the network through an autotransformer.
- Before removing the converter housing, one must switch the supply off and disconnect measuring circuits.
- The removal of the meter housing during the guarantee contract period may cause its cancellation.
- The PD10 converter is destined to be installed and used in industrial electromagnetic environment conditions.

- One must remember that in the building installation a switch or a circuit-breaker should be installed. This switch should be located near the device, easy accessible by the operator, and suitably marked.

3.2. Description of converter leads

Markings of individual leads are shown on the fig. 2




Fig. 2 External leads of the PD10 converter

External signals must be connected acc. to tables 1 and 2, in which the assignment of individual PD10 converter leads are described.

There are two diodes on the frontal plate:

Green (RxD) – signals the reception of data via RS-485.

Yellow (TxD) – signals the transmission of data via RS-485.

RS-485 interface leads

Table 1

Nr of the RS-485 pin	RS-485 signals
(5) V+	Line +5 V (for terminator)
(4) A	Line A
(3) B	Line B
(2) GND	Line GND
(1) GND	Line GND

Nr of USB pin (type B)	USB signal
1	+5 V d.c.
2	-Data
3	+Data
4	GND

3.3. Installation of the COM port for Windows

The PD10 converter makes use of FTDIBUS Driver and FTDIPOINT Driver, licensed by the Future Technology Devices International Ltd company. This software creates in the system a device of Universal Serial Bus - The **Converter USB-RS485 of PD10 type** and connected to it, the virtual COM port, named **USB-RS485 Converter Port Com of PD10 type**.

The controller installation in the Windows system causes the addition of a successive COM serial port to the list of ports serviced by the operating system.

3.4. Installation of COM port controllers on the computer

After connecting the connector to the USB port, the operating system informs about the appearance of a new device by means of a message presented on the fig. 4.

The creator to find the new hardware of the Universal Serial Bus . One must operate acc. to the creator, choosing the installation from the indicated location and giving the path to controllers being in the added CD.

Controllers are compatible with systems: Windows 2000, Windows XP, Windows Vista, Windows Server 2003 (x86 and x64).

When installing controllers, information about the lack of controller digital signature can occur. One must ignore this information and further continue the installation.




Fig. 3 Systemic message about the detection of the PD10 converter through the System

After the creator closure, the system immediately detects the next device – USB Serial Port (fig. 4). The creator to find new hardware will be started again.




Fig. 4 Systemic message about the find of a new device.

After a successful termination of the installation, the system informs about the installation of the new hardware (fig.5) In the Device Manager, two new devices appear:

- **Converter USB—RS485 of P10 type** and Port COM named: **Converter USB-RS485 of PD10 type**, acc. the fig. 6.




Fig. 5 Systemic message ending the installation of PD10 controllers




Fig. 6. Correct installation of PD10 in the Win32 system

3.5. Example of Lumel Heat and Lumel 3000 configuration to co-operate wit PD10

Lumel Heat and Lumel Energy systems communicate with industrial devices by means of COM serial ports.

After the installation of additional virtual COM serial ports, one can appeal to them in systems of Lumel series. Then, one must introduce or modify supervising appeals to added communication ports in new or existing applications or system configurations.

4. OPERATION DESCRIPTION

The RS-485 standard enables the data exchange of half duplex type. That means that they can be in the same time transmitted or received. PD10 converters can work with a maximal baud rate up to 1 Mb/s depending on the line length (e.g. 9600 kb/s on lines up to 1000 m long, 1 Mb/s on lines up to 10 m long). At lines over 800 m, between lines A and B of the RS-485 interface, one must use terminators (resistors) on ends of the bus. The terminator value should be adapted to the application.

In the environment with unknown interference level it is recommended to observe following principles:



- Connections of communication interface circuits must be conducted individually by twisted wires in a screen.
- Apply the general principle that wires (group of wires) leading different signals should be led in the possible farthest distance between them (not less than 50 cm) and the crossing of such group of wires should be made at right angle.
- The device does not fulfil requirements concerning the electromagnetic compatibility in residential environment

5. TECHNICAL DATA

Transmission data

- baud rate up to 1000 kb/s, depending on the line length
- data flow direction control automatic
- controllers Windows 2000, XP, Server 2003, Vista, Server 2008 (x86 and x64).

Converter power consumption

≤ 1,5 W

Rated operation conditions:

- supply voltage 5 V d.c., from the USB port
- ambient temperature 0...55°C
- relative humidity < 85%
- working position any

Storage and transport conditions:

- ambient temperature 0...70°C
- relative humidity < 85%

Ensured protection grades (EN 60529):

- from the housing side IP 40
- from the terminal side IP 20

Dimensions

52 × 44 × 24 mm

Weight

0,1 kg

Electromagnetic compatibility:

- immunity EN 61000-6-2
- emission EN 61000-6-4

Maximal working voltage in relation to earth:

< 50 V

6. EXECUTION AND ORDERING CODES

PD10 execution codes

Table 3

CONVERTER	PD10 -	1	XX	X
Kind of execution				
katalogue			00	
custom-made*			XX	
Acceptance tests				
without extra requirements				8
with an extra quality inspection certificate				7
other requirements*				X

* The execution code is established by the manufacturer

Example of ordering:

PD10 - 1 0 7 code means:

PD10 - USB-RS485 interface converter :

1 - with galvanic insulation

00 - catalogue execution

7 - with an extra quality inspection certificate

7. MAINTENANCE AND GUARANTEE

The PD10 converter does not require any periodical maintenance. In case of some incorrect operations:

1. After the dispatch date and within the period stated in the guarantee card

One should return the instrument to the manufacturer's Quality Inspection Dept.

If the instrument has been used in compliance with the instructions, the manufacturer guarantees to repair it free of charge.

The disassembling of the housing causes the cancellation of the granted guarantee.

2. After the guarantee period:

One should send the instrument to repair it in an authorized service workshop.

Our policy is one of continuous improvement and we reserve the right to make changes in design and specifications of any products as engineering advances or necessity requires and revise the above specifications without notice.

SALES PROGRAM

- DIGITAL and BARGRAPH PANEL METERS
- MEASURING TRANSDUCERS
- ANALOG PANEL METERS (DIN INSTRUMENTS)
- DIGITAL CLAMP-ON METERS
- INDUSTRIAL PROCESS and POWER CONTROLLERS
- CHART and PAPERLESS RECORDERS
- LARGE SIZE DISPLAY PANELS
- ELEMENTS OF INTEGRATION SYSTEMS
- ACCESSORIES for MEASURING INSTRUMENTS (SHUNTS)
- MEASURING SYSTEMS (ENERGY, HEAT, CONTROL)
- CUSTOM-MADE PRODUCTS ACCORDING CUSTOMER'S REQUIREMENTS

MEASUREMENT CONTROL RECORDING

WE ALSO OFFER OUR SERVICES IN THE PRODUCTION OF:

- ALUMINIUM ALLOY PRESSURE CASTINGS
- PRECISION ENGINEERING and THERMOPLASTICS PARTS
- SUBCONTRACTING of ELECTRONIC DEVICES (SMT)
- PRESSURE CASTINGS and OTHER TOOLS

QUALITY PROCEDURES:

According to ISO 9001 and ISO 14001 international requirements.

All our instruments have CE mark.

For more information, please write to or phone our Export Department



Lubuskie Zakłady Aparatów Elektrycznych LUMEL S.A.

ul. Sulechowska 1, 65-022 Zielona Góra, Poland

Tel.: (48-68) 329 51 00 (exchange)

Fax: (48-68) 329 51 01

e-mail: lumel@lumel.com.pl

<http://www.lumel.com.pl>

Export Department:

Tel.: (48-68) 329 53 02

Fax: (48-68) 325 40 91

e-mail: export@lumel.com.pl